


To properly insulate through a roof top duct support; lift duct off of support, insulate duct through the support, install Alumaguard through the support and add an additional layer of Alumaguard 6" wide on the bottom and both sides at the point of contact with the support system. If duct cannot be lifted off supports, see Detail Drawing 2 "Insulating duct on supports"

6" STRIP OF ALUMAGUARD ON BOTTOM AND SIDES AT POINT OF CONTACT WITH DUCT SUPPORT SYSTEM



SECTION @ INSULATING DUCT AT SUPPORTS DETAIL 1

POLYGUARD PRODUCTS, INC. 2011

(NOT TO SCALE)