





LOW-RISE SPRAY ADHESIVE (BY OTHERS)

WALL TIE, FASTENER HOLE SEALED AND TOOLED WITH POLYGUARD DETAIL SEALANT PW BETWEEN BACK OF WALL TIE AND POLYGUARD AIR BARRIER FIELD MEMBRANE

INSULATION, IDENTIFY TYPE AND LOCATION

POLYGUARD VAPOR PERMEABLE AIRLOK FLEX VP AIR BARRIER MEMBRANE APPLIED BEFORE (AS SHOWN) OR AFTER SELECTED FLASHING

GYPSUM SHEATHING

TERMINATION BAR (BY OTHERS) FOR SHEET THRU-WALL FLASHING ONLY. APPLY AND TOOL WITH POLYGUARD DETAIL SEALANT PW ALONG TOP EDGE AND OVER EACH FASTENER HEAD. TERMINATION BAR AND SEALANT ARE NOT REQUIRED IN COMBINATION WITH FLUID-APPLIED THRU-WALL FLASHING MATERIALS.

POLYGUARD AIRLOK SHEET 200 BU / NP, AIRLOK SHEET 400 NP, OR AIRLOK SHEET 400 HT / NP APPLIED OVER POLYGUARD 650 LT LIQUID ADHESIVE OR CALIFORNIA SEALANT APPLIED AT A RATE OF 250 - 300 SF / GAL , OR OVER 650 WB LIQUID ADHESIVE APPLIED AT A RATE OF 350 - 400 SF / GAL (END DAMS NOT SHOWN); OR OVER POLYGUARD DETAIL SEALANT PW APPLIED AND TOOLED TO MINIMUM 25 MILS WET. TERMINATE / TRIM SELECTED FLASHING 5/8" FROM BEND IN COUNTER FLASHING.

POLYGUARD DETAIL SEALANT PW APPLIED AND TOOLED TO FORM A 3/4" CANT
WEEP HOLES (BEYOND)

COUNTER FLASHING (BY OTHERS) FOR MEMBRANE UV PROTECTION

LINE OF GRADE

POLYGUARD BELOW-GRADE WATERPROOFING SYSTEM WITH DRAINBOARD; REFERENCE BELOW-GRADE WATERPROOFING SYSTEM FOR TRANSITIONS AND DETAILS

01

SECTION @ FRAMED BACKING WALL / MASONRY VENEER - WALL BASE

AFFP

Polyguard Products, Inc. P.O. Box 755 - Ennis, TX 75120 Phone: 214-515-5000 Web Site - www.polyguard.com ©POLYGUARD PRODUCTS, INC. MATERIAL SEPARATED FOR CLARITY

The information provided is based on data and knowledge considered to be true and accurate and is offered for the users' consideration, investigation and verification, but we do not warrant the results to be obtained. Please read all data sheets, statements, recommendations or suggestions in conjunction with our conditions of sale which apply to all goods supplied by us

NOT TO SCALE EFFECTIVE DATE: 03/06/2023 SUPERCEDES:

01/01/2023