





LOW-RISE SPRAY ADHESIVE (BY OTHERS)

INSULATION, IDENTIFY TYPE AND LOCATION

WALL TIE, FASTENER HOLE SEALED AND TOOLED WITH POLYGUARD DETAIL SEALANT PW BETWEEN BACK OF WALL TIE AND POLYGUARD AIR BARRIER FIELD MEMBRANE

POLYGUARD VAPOR PERMEABLE AIRLOK FLEX VP AIR BARRIER MEMBRANE APPLIED BEFORE (AS SHOWN) OR AFTER SELECTED FLASHING

GYPSUM SHEATHING

TERMINATION BAR (BY OTHERS) FOR SHEET THRU-WALL FLASHING ONLY. APPLY AND TOOL WITH POLYGUARD DETAIL SEALANT PW ALONG TOP EDGE AND OVER EACH FASTENER HEAD. TERMINATION BAR AND SEALANT ARE NOT REQUIRED IN COMBINATION WITH FLUID-APPLIED THRU-WALL FLASHING MATERIALS.

POLYGUARD AIRLOK SHEET 200 BU / NP, AIRLOK SHEET 400 NP, OR AIRLOK SHEET 400 HT / NP APPLIED OVER POLYGUARD 650 LT LIQUID ADHESIVE OR CALIFORNIA SEALANT APPLIED AT A RATE OF 250 - 300 SF / GAL, OR OVER 650 WB LIQUID ADHESIVE APPLIED AT A RATE OF 350 - 400 SF / GAL; OR OVER POLYGUARD DETAIL SEALANT PW APPLIED AND TOOLED TO MINIMUM 25 MILS WET. EXTEND SELECTED FLASHING MEMBRANE A MINIMUM 3" ONTO AIR BARRIER MEMBRANE AND TERMINATE 5/8" FROM BEND IN DRIP EDGE (END DAMS NOT SHOWN). APPLY SELECTED FLASHING MATERIAL EITHER BEFORE OR AFTER (AS SHOWN) POLYGUARD AIR BARRIER MEMBRANE.

CONNECTION BETWEEN FLOOR PLATE AND SHELF ANGLE PER ENGINEERING DETAILS

3/4" CANT OF POLYGUARD DETAIL SEALANT PW APPLIED AND TOOLED ALONG SELECTED AIR BARRIER MEMBRANE AND SHELF ANGLE JOINT

STAINLESS STEEL OR COPPER DRIP EDGE

COMPRESSIBLE PAD

POLYGUARD AIRLOK SHEET 200 BU / NP, AIRLOK SHEET 400 NP, OR AIRLOK SHEET 400 HT / NP APPLIED OVER POLYGUARD 650 LT LIQUID ADHESIVE OR CALIFORNIA SEALANT APPLIED AT A RATE OF 250 - 300 SF / GAL. OR OVER 650 WB LIQUID ADHESIVE APPLIED AT A RATE OF 350 - 400 SF / GAL: OR OVER POLYGUARD DETAIL SEALANT PW APPLIED AND TOOLED TO MINIMUM 25 MILS WET. EXTEND SELECTED FLASHING MEMBRANE A MINIMUM 3" ONTOTHE AIR BARRIER MEMBRANE. APPLY SELECTED FLASHING MATERIAL EITHER BEFORE OR AFTER (AS SHOWN) POLYGUARD AIR BARRIER MEMBRANE.

POLYGUARD VAPOR PERMEABLE AIRLOK FLEX VP AIR BARRIER MEMBRANE APPLIED BEFORE (AS SHOWN) OR AFTER SELECTED FLASHING

SECTION @ FRAMED BACKING WALL / MASONRY VENEER - FLOOR TRANSITION

AFFP

02

Polyguard Products, Inc. P.O. Box 755 - Ennis. TX 75120 Phone: 214-515-5000 Web Site - www.polyguard.com

The information provided is based on data and knowledge considered to be true and accurate and is offered for the users' consideration, investigation and verification, but we do not warrant the results to be obtained. Please

read all data sheets, statements, recommendations, or suggestions in con-

NOT TO SCALE EFFECTIVE DATE: 03/06/2023 SUPERCEDES: junction with our conditions of sale, which apply to all goods supplied by us. 01/01/2023

©POLYGUARD PRODUCTS, INC. MATERIAL SEPARATED FOR CLARITY