



WALL TIE, FASTENER HOLE SEALED AND TOOLED WITH POLYGUARD DETAIL SEALANT PW BETWEEN BACK OF WALL TIE AND AIR BARRIER FIELD MEMBRANE

RIGID INSULATION

POLYGUARD NON-PERMEABLE AIRLOK SHEET 200 BU SERIES AIR BARRIER MEMBRANE APPLIED BEFORE (AS SHOWN) OR AFTER SELECTED FLASHING

GYPSUM SHEATHING

TERMINATION BAR (BY OTHERS) FOR SHEET THRU-WALL FLASHING ONLY. APPLY AND TOOL WITH POLYGUARD DETAIL SEALANT PW OR AIRLOK DETAIL-N-JOINT ALONG TOP EDGE AND OVER EACH FASTENER HEAD. TERMINATION BAR AND SEALANT ARE NOT REQUIRED IN COMBINATION WITH FLUID-APPLIED THRU-WALL FLASHING MATERIALS.

POLYGUARD AIRLOK SHEET 200 BU / NP, AIRLOK SHEET 400 NP, OR AIRLOK SHEET 400 HT / NP APPLIED OVER POLYGUARD 650 LT LIQUID ADHESIVE OR CALIFORNIA SEALANT APPLIED AT A RATE OF 250 - 300 SF / GAL, OR OVER 650 WB LIQUID ADHESIVE APPLIED AT A RATE OF 350 - 400 SF / GAL; OR POLYGUARD DETAIL SEALANT PW APPLIED AND TOOLED TO MINIMUM 25 MILS WET; EXTEND SELECTED FLASHING MEMBRANE A MINIMUM 3" ONTO AIR BARRIER MEMBRANE AND TERMINATE 5/8" FROM BEND IN DRIP EDGE (END DAMS NOT SHOWN). APPLY SELECTED FLASHING MATERIAL EITHER BEFORE OR AFTER (AS SHOWN) SELECTED POLYGUARD AIR BARRIER MEMBRANE.

CONNECTION BETWEEN FLOOR PLATE AND SHELF ANGLE PER ENGINEERING DETAILS

POLYGUARD DETAIL SEALANT PW APPLIED AND TOOLED TO MINIMUM 3/4" CANT / FILLET ALONG SELECTED AIR BARRIER MEMBRANE AND SHELF ANGLE JOINT

STAINLESS STEEL OR COPPER DRIP EDGE

LIP BRICK

COMPRESSIBLE PAD

POLYGUARD AIRLOK SHEET 200 BU / NP, AIRLOK SHEET 400 NP, OR AIRLOK SHEET 400 HT / NP APPLIED OVER POLYGUARD 650 LT LIQUID ADHESIVE OR CALIFORNIA SEALANT APPLIED AT A RATE OF 250 - 300 SF / GAL, OR OVER 650 WB LIQUID ADHESIVE APPLIED AT A RATE OF 350 - 400 SF / GAL; OR POLYGUARD DETAIL SEALANT PW APPLIED AND TOOLED TO MINIMUM 25 MILS WET; EXTEND SELECTED FLASHING MINIMUM 3" ONTO AIR BARRIER MEMBRANE. APPLY SELECTED FLASHING EITHER BEFORE OR AFTER (AS SHOWN) SELECTED POLYGUARD AIR BARRIER MEMBRANE.

POLYGUARD NON-PERMEABLE AIRLOK SHEET 200 BU SERIES AIR BARRIER MEMBRANE APPLIED BEFORE (AS SHOWN) OR AFTER SELECTED FLASHING

02

**SECTION @ FRAMED BACKING WALL / MASONRY VENEER - FLOOR TRANSITION**

ASBNP

Polyguard Products, Inc.  
P.O. Box 755 - Ennis, TX 75120  
Phone: 214-515-5000  
Web Site - www.polyguard.com

©POLYGUARD PRODUCTS, INC.  
MATERIAL SEPARATED FOR CLARITY

<p>The information provided is based on data and knowledge considered to be true and accurate and is offered for the users' consideration, investigation and verification, but we do not warrant the results to be obtained. Please read all data sheets, statements, recommendations or suggestions in conjunction with our conditions of sale, which apply to all goods supplied by us.</p>	NOT TO SCALE
	EFFECTIVE DATE: 05/10/2024
	SUPERCEDES: 10/01/2022