

DETAIL

(MIN.) 5

RIGID INSULATION

POLYGUARD NON-PERMEABLE AIRLOK SHEET 200 BU / NP MEMBRANE APPLIED BEFORE (AS SHOWN) OR AFTER SELECTED FLASHING

WALL TIE, FASTENER HOLE SEALED AND TOOLED WITH POLYGUARD DETAIL SEALANT PW BETWEEN BACK OF WALL TIE AND AIRLOK SHEET 200 BU / NP MEMBRANE

TERMINATION BAR (BY OTHERS) FOR SHEET THRU-WALL FLASHING ONLY. APPLY AND TOOL WITH POLYGUARD DETAIL SEALANT PW ALONG TOP EDGE AND OVER EACH FASTENER HEAD. TERMINATION BAR AND SEALANT ARE NOT REQUIRED IN COMBINATION WITH FLUID-APPLIED THRU-WALL FLASHING MATERIALS.

POLYGUARD AIRLOK SHEET 200 BU / NP, AIRLOK SHEET 400 NP, OR AIRLOK SHEET 400 HT / NP APPLIED OVER POLYGUARD 650 LT LIQUID ADHESIVE OR CALIFORNIA SEALANT APPLIED AT A RATE OF 250 - 300 SF / GAL, OR OVER 650 WB LIQUID ADHESIVE APPLIED AT A RATE OF 350 - 400 SF / GAL; OR POLYGUARD DETAIL SEALANT PW APPLIED AND TOOLED TO MINIMUM 25 MILS WET; EXTEND SELECTED FLASHING MEMBRANE A MINIMUM 3" ONTO AIRLOK SHEET 200 BU / NP MEMBRANE AND TERMINATE 5/8" FROM BEND IN DRIP EDGE (END DAMS NOT SHOWN). APPLY SELECTED FLASHING MATERIAL EITHER BEFORE OR AFTER (AS SHOWN) POLYGUARD AIRLOK SHEET 200 BU / NP MEMBRANE.

SHELF ANGLE PER ENGINEERING DETAILS

WEEP HOLES (BEYOND)

BACKER ROD AND SEALANT (BY OTHERS)

STAINLESS STEEL OR COPPER DRIP EDGE

- NON-FLANGED WINDOW DOOR OR FIXTURE (WINDOW SHOWN)

SECTION @ FRAMED BACKING WALL / MASONRY VENEER - NON-FLANGED WINDOW, DOOR, OR FIXTURE HEAD

©POLYGUARD PRODUCTS, INC. MATERIAL SEPARATED FOR CLARITY

The information provided is based on data and knowledge considered to be

true and accurate and is offered for the users' consideration, investigation

and verification, but we do not warrant the results to be obtained. Please read all data sheets, statements, recommendations or suggestions in con-

junction with our conditions of sale, which apply to all goods supplied by us

NOT TO SCALE

SUPERCEDES:

09/19/2024

07/15/2024

EFFECTIVE DATE

Polyguard Products, Inc. P.O. Box 755 - Ennis, TX 75120 Phone: 214-515-5000 Web Site - www.polyguard.com

03

ASBNP