





POLYGUARD BLINDSIDE MEMBRANE FABRIC FACING CONCRETE POUR OR SHOTCRETE WHEN NOT IN WATER TABLE - IF IN WATER TABLE CONSULT POLYGUARD - APPLIED BEHIND EXISTING BLINDSIDE SHEET A MAXMIUM 4"

TROWELED BEAD OF POLYGUARD DETAIL SEALANT PW OR POLYGUARD LM-95 APPLIED TO TOP TERMINATION OF POLYGUARD BLINDSIDE MEMBRANE. PREPARE FABRIC WITH POLYGUARD 650 LT LIQUID ADHESIVE OR POLYGUARD CALIFORNIA SEALANT AT A RATE OF 50 - 75 SF/GAL

APPLY FASTENERS AT NOT GREATER THAN 12" SPACING AFTER SECOND LIFT IS IN PLACE - BY OTHERS

12" STRIP OF POLYGUARD FABRIC TAPE CENTERED AND ADHERED ACROSS THE ENDLAP SEAM - EXTEND TO 6" BEYOND EACH SIDE SEAM OF ENDLAP - PREPARE FABRIC BEING COVERED WITH POLYGUARD 650 LT LIQUID ADHESIVE OR POLYGUARD CALIFORNIA SEALANT APPLIED AT A RATE OF 50 - 75 SF/GAL

APPLY FASTENERS NOT GREATER THAN 12" SPACING TO HOLD POLYGUARD BLINDSIDE MEMBRANE IN PLACE PRIOR TO SECOND LIFT PLACEMENT - BY OTHERS

POLYGUARD BLINDSIDE MEMBRANE FABRIC FACING CONCRETE POUR - FOLD BACK A MAXIMUM OF 4" FLAP AND PROTECT UNTIL PLACEMENT OF NEXT SHEET OF POLYGUARD BLINDSIDE MEMBRANE SHEET

BS7

SECTION @ END LAP

©POLYGUARD PRODUCTS, INC. MATERIAL SEPARATED FOR CLARITY

Polyguard Products, Inc. P.O. Box 755 - Ennis, TX 75120 Phone: 214-515-5000 Web Site - www.polyguard.com The information provided is based on data and knowledge considered to be true and accurate and is offered for the users' consideration, investigation and verification, but we do not warrant the results to be obtained. Please read all data sheets, statements, recommendations or suggestions in conjunction with our conditions of sale, which apply to all goods supplied by us

NOT TO SCALE

EFFECTIVE DATE:
12/16/2024

SUPERCEDES:

07/15/2024