



POLYGUARD POLYFLOW 15 MOLDED SHEET DRAINAGE FABRIC TOWARD BACKFILL

MINIMUM 90 MILS OF POLYGUARD CR LIQUID MEMBRANE APPLIED TO SUBSTRATE PREPARED WITH POLYGUARD CR SEALANT AT A RATE OF OF 175 - 200 SF/GAL - TO CLEAN, DRY FROST FREE HDPE A MINIMUM OF 1" TO EACH SIDE OF EDGE

CONCRETE WALL - BY OTHERS

POLYGUARD ULTRA CRM MEMBRANE APPLIED TO CLEAN DRY AND FROST FREE CONCRETE PREPARED WITH POLYGUARD 650 LT LIQUID ADHESIVE OR POLYGUARD CALIFORNIA SEALANT APPLIED AT A RATE OF 250 - 300 SF/GAL

MINIMUM 90 MIL THICKNESS OF POLYGUARD LM-95 EXTENDED ONTO A MINIMUM OF 2" TO EACH SIDE OF THE JOINT OR 12" STRIP OF POLYGUARD DETAIL TAPE APPLIED TO PREPARED SUBSTRATE

WATERSTOP BY OTHERS

CONCRETE SLAB - BY OTHERS

CRM MEMBRANE FABRIC TOWARD CONCRETE POUR

POLYGUARD POLYFLOW 18 MOLDED SHEET DRAINAGE FABRIC TOWARD SUBSTRATE

APPROVED SUBSTRATE - BY OTHERS

CRH8

SECTION @ ULTRA CRM TIE IN TO EMBEDDED CRM MEMBRANE - PROFILE 2

©POLYGUARD PRODUCTS, INC.
MATERIAL SEPARATED FOR CLARITY

Polyguard Products, Inc.
P.O. Box 755 - Ennis, TX 75120
Phone: 214-515-5000
Web Site - www.polyguard.com

<small>The information provided is based on data and knowledge considered to be true and accurate and is offered for the users' consideration, investigation and verification, but we do not warrant the results to be obtained. Please read all data sheets, statements, recommendations or suggestions in conjunction with our conditions of sale, which apply to all goods supplied by us.</small>	NOT TO SCALE
	EFFECTIVE DATE: 10/01/2022
	SUPERCEDES: 02/04/2022