


DETAIL

1/8" x 1" METAL TERMINATION STRIP ALIGNED ALONG TOP EDGE OF POLYGUARD ULTRA CRM MEMBRANE AND FASTENED NOT GREATER THAN 8" SPACING - BY OTHERS POLYGUARD POLYFLOW 15 MOLDED SHEET DRAIN - FABRIC TOWARD RETENTION SYSTEM 12" STRIP OF POLYGUARD 606 TAPE APPLIED TO CLEAN, DRY AND FROST FREE CONCRETE PREPARED WITH POLYGUARD 650 LT LIQUID ADHESIVE OR POLYGUARD CALIFORNIA SEALANT APPLIED AT A RATE OF 250 - 300 SF/GAL 12" POLYGUARD CRM MEMBRANE TAIL APPLIED OVER 12" STRIP OF POLYGUARD 606 **TAPE - PREPARE FABRIC SIDE** OF POLYGUARD CRM MEMBRANE WITH POLYGUARD 650 LT LIQUID ADHESIVE OR POLYGUARD CALIFORNIA SEALANT AT A RATE OF 50 - 75 SF/GAL



MINIMUM 90 MILS OF POLYGUARD CR LIQUID MEMBRANE APPLIED TO THE TERMINAL EDGE OF TERMINATION STRIP COVERING FASTENERS AND EXTENDING 1/2" ABOVE AND BELOW TERMINATION STRIP - PREPARE SURFACE WITH POLYGUARD CR SEALANT AT A RATE OF 175 - 200 SF/GAL PRIOR TO POLYGUARD CR LIQUID MEMBRANE

CLEAN DRY FROST FREE CONCRETE - BY OTHERS

MINIMUM 90 MILS OF POLYGUARD CR LIQUID MEMBRANE APPLIED TO THE TERMINAL EDGE OF POLYGUARD ULTRA CRM MEMBRANE AND EXTENDING 1/2" BEYOND TERMINAL EDGE IN BOTH DIRECTIONS -PREPARE SURFACE WITH POLYGUARD CR SEALANT AT A RATE OF 175 - 200 SF/GAL PRIOR TO POLYGUARD CR LIQUID MEMBRANE OR APPLY A STRIP OF POLYGUARD CR SEAM TAPE CENTERED OVER TERMINATION

POLYGUARD ULTRA CRM MEMBRANE APPLIED TO CLEAN, DRY AND FROST FREE SUBSTRATE PREPARED WITH POLYGUARD 650 LT LIQUID ADHESIVE OR POLYGUARD CALIFORNIA SEALANT AT A RATE OF 250 - 300 SF/GAL



©POLYGUARD PRODUCTS, INC. MATERIAL SEPARATED FOR CLARITY

Polyguard Products, Inc. P.O. Box 755 - Ennis, TX 75120 Phone: 214-515-5000 Web Site - www.polyguard.com

The information provided is based on data and knowledge considered to be true and accurate and is offered for the users' consideration, investigation and verification, but we do not warrant the results to be obtained. Please and all data shees, statements, recommendations or suggestions in conjunction with our conditions of sale, which apply to all goods supplied by us 10/01/20222