
STEP 2





POLYGUARD POLYFLOW 15 MOLDED DRAINAGE BOARD - FABRIC FACING RETENTION SYSTEM

TEMPORARY FASTENER - BY OTHERS

POLYGUARD CRM MEMBRANE FABRIC FACING CONCRETE POUR - APPLY THE POLYGUARD CRM MEMBRANE TO THE BOTTOM HALF OF THE OF POLYGUARD CR SEAM TAPE WITH BOTTOM HALF OF RELEASE FILM REMOVED. LEAVE THE REMAINDER OF THE POLYGUARD CRM MEMBRANE UNADHERED. ANCHOR THROUGH DRAINBOARD INTO SUBSTRATE FOR TEMPORARY ATTACHMENT.

APPLY POLOYGUARD CR SEAM TAPE OVER LOW RISE SPRAY ADHESIVE ONLY REMOVING HALF OF THE FILM STICK THE POLYGUARD CRM MEMBRANE INTO THE LOW RISE SPRAY ADHESIVE - LEAVING THE OTHER HALF OF FILM ON THE POLYGUARD CR SEAM TAPE FOR FUTURE TIE IN ASSEMBLY

SPRAY A 12" WIDE AREA OF LOW RISE SPRAY ADHESIVE ONTO DRAINBOARD AND ONTO POLYGUARD CR SEAM TAPE - ALLOW TO FLASH OFF AND PRESS THE POLYGUARD CRM MEMBRANE AND POLYGUARD CR SEAM TAPE INTO ADHESIVE ON THE POLYGUARD POLYFLOW 15

NEXT SUCCEEDING SHEET OF POLYGUARD CRM MEMBRANE - FABRIC TOWARD CONCRETE POUR APPLIED OVER POLYGUARD CR SEAM TAPE WITH RELEASE LINER REMOVED

COVERING BEAD OF POLYGUARD DETAIL SEALANT PW OR POLYGUARD LM-95 APPLIED TO FABRIC OF POLYGUARD CRM MEMBRANE. PREPARE FABRIC WITH POLYGUARD 650 LT LIQUID ADHESIVE OF POLYGUARD CALIFORNIA SEALANT AT A RATE OF 50 - 75 SF/GAL

REMOVE THE REMAINDER OF THE RELEASE LINER THAT WAS LEFT ON THE POLYGUARD CR SEAM TAPE AND APPLY THE POLYGUARD CRM MEMBRANE TO IT

APPLY 90 MILS OF POLYGUARD CR LIQUID MEMBRANE ONTO POLYGUARD CRM MEMBRANE A MAXIMUM OF 4" - PREPARE FABRIC WITH POLYGUARD CR SEALANT APPLIED AT A RATE OF 50 - 75 SF/GAL

CUT THE POLYGUARD CRM MEMBRANE JUST BELOW THE TEMPORARY ANCHOR. DO NOT CUT THE TAIL OF THE POLYGUARD CRM MEMBRANE OFF THIS WILL BE USED FOR TIE IN ASSEMBLY COMPLETION

12" STRIP OF POLYGUARD FABRIC TAPE CENTERED AND ADHERED ACROSS THE END LAP SEAM - EXTEND TO 6" BEYOND EACH SIDE SEAM OF END LAP - PREPARE FABRIC BEING COVERED WITH POLYGUARD 650 LT LIQUID ADHESIVE OR POLYGUARD CALIFORNIA SEALANT AT A RATE OF 50 - 75 SF/GAL



STEP 1

SECTION @ CRM MEMBRANE TEMPORARY END LAP SECUREMENT AT TOP OF LIFT

©POLYGUARD PRODUCTS, INC. MATERIAL SEPARATED FOR CLARITY

The information provided is based on data and knowledge considered to be true and accurate and is offered for the users' consideration, investigation and verification, but we do not warrant the results to be obtained. Please read all data sheets, statements, recommendations or suggestions in conjunction with our conditions of sale, which apply to all goods supplied by us

4" MAX

NOT TO SCALE

EFFECTIVE DATE:
10/01/2022

SUPERCEDES:
01/09/2017

Polyguard Products, Inc. P.O. Box 755 - Ennis, TX 75120 Phone: 214-515-5000 Web Site - www.polyguard.com