





RIGID INSULATION

LOW-RISE SPRAY ADHESIVE (BY OTHERS)

POLYGUARD NON-PERMEABLE STRETCH FLEX AIR BARRIER MEMBRANE APPLIED BEFORE (AS SHOWN) OR AFTER SELECTED FLASHING

WALL TIE, FASTENER HOLE SEALED AND TOOLED WITH POLYGUARD DETAIL SEALANT PW BETWEEN BACK OF WALL TIE AND AIR BARRIER FIELD MEMBRANE

TERMINATION BAR (BY OTHERS) FOR SHEET THRU-WALL FLASHING ONLY. APPLY AND TOOL WITH POLYGUARD DETAIL SEALANT PW ALONG TOP EDGE AND OVER EACH FASTENER HEAD. TERMINATION BAR AND SEALANT ARE NOT REQUIRED IN COMBINATION WITH FLUID-APPLIED THRU-WALL FLASHING MATERIALS.

POLYGUARD AIRLOK SHEET 200 BU / NP, AIRLOK SHEET 400 NP, OR AIRLOK SHEET 400 HT / NP APPLIED OVER POLYGUARD 650 LT LIQUID ADHESIVE OR CALIFORNIA SEALANT APPLIED AT A RATE OF 250 - 300 SF / GAL, OR OVER 650 WB LIQUID ADHESIVE APPLIED AT A RATE OF 350 - 400 SF / GAL; OR POLYGUARD DETAIL SEALANT PW APPLIED AND TOOLED TO MINIMUM 25 MILS WET; EXTEND SELECTED FLASHING MEMBRANE A MINIMUM 3" ONTO AIR BARRIER MEMBRANE AND TERMINATE 5/8" FROM BEND IN DRIP EDGE (END DAMS NOT SHOWN). APPLY SELECTED FLASHING MATERIAL EITHER BEFORE OR AFTER (AS SHOWN) POLYGUARD AIR BARRIER MEMBRANE.

SHELF ANGLE PER ENGINEERING DETAILS

WEEP HOLES (BEYOND)

BACKER ROD AND SEALANT (BY OTHERS)

STAINLESS STEEL OR COPPER DRIP EDGE (BY OTHERS)

NON-FLANGED WINDOW DOOR OR FIXTURE (WINDOW SHOWN)

03

SECTION @ FRAMED BACKING WALL / MASONRY FINISH - NON-FLANGED WINDOW, DOOR, OR FIXTURE HEAD

SFAG

The information provided is based on data and knowledge considered to be true and accurate and is offered for the users' consideration, investigation and verification, but we do not warrant the results to be obtained. Please read all data sheets, statements, recommendations, or suggestions in con-

©POLYGUARD PRODUCTS, INC. MATERIAL SEPARATED FOR CLARITY