



POLYGUARD 606 TAPE APPLIED TO CONCRETE PREPARED WITH POLYGUARD 650 LT LIQUID ADHESIVE OR POLYGUARD CALIFORNIA SEALANT APPLIED AT A RATE OF 250 - 300 SF / GAL

POLYGUARD PREFORMED US OUTSIDE CORNER BOOT ADHERED TO POLYGUARD 606 TAPE - TRIM **EXCESS MATERIAL ABOVE** POLYGUARD 606 TAPE

POLYGUARD UNDERSLAB MEMBRANE WITH FABRIC TOWARD CONCRETE POUR AND TIGHT FIT AROUND THE BASE OF THE CORNER/COLUMN



TOP EDGE OF POLYGUARD UNDERSLAB 'SKIRT' ALIGNED AND ADHERED TO TOP EDGE AND BODY OF POLYGUARD 606 TAPE AND THE EXPOSED BOOT COMPOUND. EXTEND FIELD LEG OF THE 'SKIRT' 6" ONTO THE FIELD MEMBRANE FABRIC AND EXPOSED BOOT COMPOUND.



- MINIMUM 90 MILS OF POLYGUARD DETAIL SEALANT PW OR POLYGUARD LM-95 APPLIED TO CLEAN, DRY, AND FROST FREE CONCRETE; ALONG THE TOP EDGE OF THE TERMINATION STRIP; OVER FASTENER HEADS: AND ONTO 1" OF THE FABRIC BELOW THE **TERMINATION STRIP**
- FASTENERS SPACED 2" INWARD FROM EACH CORNER AND NOT MORE THAN 8" SPACING BETWEEN ENDS - BY OTHERS
- 1/8" X 1" METAL TERMINATION STRIP ALIGNED ALONG THE TOP EDGE OF POLYGUARD UNDERSLAB MEMBRANE 'SKIRT' AND POLYGUARD **606 TAPE**
- PREPARE AND CLEAN THE FABRIC 6" TO EACH SIDE OF THE 'SKIRT' EDGE. APPLY POLYGUARD 650 LT LIQUID ADHESIVE OR POLYGUARD CALIFORNIA SEALANT TO THE CLEANED AREA AT A RATE OF 50-75 SF / GAL.
- COVER THE ADHESIVE OR SEALANT WITH POLYGUARD FABRIC TAPE. ROLL THE POLYGUARD FABRIC TAPE WITH A HAND-HELD. HARD-SURFACE ROLLER.

JS17

PREFORMED US OUTSIDE CORNER BOOT AT CONCRETE COLUMN

Polyguard Products, Inc. P.O. Box 755 - Ennis. TX 75120 Phone: 214-515-5000 Web Site - www.polyguard.com

©POLYGUARD PRODUCTS, INC. MATERIAL SEPARATED FOR CLARITY

The information provided is based on data and knowledge considered to be true and accurate and is offered for the users' consideration, investigation and verification, but we do not warrant the results to be obtained. Please read all data sheets, statements, recommendations or suggestions in conjunction with our conditions of sale, which apply to all goods supplied by us

NOT TO SCALE **EFFECTIVE DATE:** 10/01/2022 SUPERCEDES: 02/01/2022