



- REPLACEMENT CONCRETE
- SEAL ALL CROSS SAW CUTS WITH INJECTABLE MATERIAL (BY OTHERS)
- POLYGUARD LM-95 OR TRM SEALANT APPLIED OVER CLEAN, DRY, FROST-FREE EXISTING CONCRETE SLAB; OVER AND ALONG TERMINATION BAR TOP EDGE; OVER EACH TERMINATION BAR FASTENER HEAD; AND ONTO MINIMUM 1" OF POLYGUARD UNDERSLAB TRM FABRIC BELOW TERMINATION BAR PREPARED WITH POLYGUARD 650 LT LIQUID ADHESIVE OR CALIFORNIA SEALANT APPLIED AT A RATE OF 50 - 75 SF / GAL
- 1/8" X 1" METAL TERMINATION BAR WITH FASTENERS (BY OTHERS) SPACED 2" INWARD FROM EACH END OF TERMINATION BAR AND NOT MORE THAN 8" SPACING BETWEEN FASTENERS
- NEW PIECE OF POLYGUARD UNDERSLAB TRM ON BOTTOM OF TRENCH; ADHERE FILM SIDE VERTICALLY TO POLYGUARD 606 TAPE AND TO CORNER BOOT IN CORNERS (SHOWN)
- PLACE POLYGUARD US INSIDE CORNER BOOT HORIZONTAL LEG ONTO ASPHALT SIDE OF CLEAN AND DRY POLYGUARD TERM FOUNDATION WATER / TERMITE BARRIER AND INTO CORNER FOR BOND WITH 606 TAPE; REFERENCE POLYGUARD TRM STANDARD DETAILS (TU20) AND (TU21) FOR FIELD-FABRICATE OPTION DIRECTIONS ON INSIDE CORNER
- EXISTING POLYGUARD UNDERSLAB TRM TO REMAIN
- POLYGUARD 606 TAPE APPLIED TO CLEAN, DRY, FROST-FREE EXISTING CONCRETE SLAB SIDE WALL OF TRENCH PREPARED WITH POLYGUARD 650 LT LIQUID ADHESIVE OR CALIFORNIA SEALANT APPLIED AT A RATE OF 250 -300 SF / GAL
- POLYGUARD 650 TRM 12" PIECE APPLIED TO EXISTING UNDERSLAB TRM CLEANED FILM SIDE, LEAVING FILM ON EXPOSED SIDE OF 650 TRM; THEN ANCHOR TO SIDE OF TRENCH TO PROTECT 650 TRM FROM BACKFILLING DAMAGE. ONCE BACKFILLED, LAY TAPED PIECE TO BOTTOM OF TRENCH AND REMOVE FILM FOR ADHESION OF POLYGUARD BOOT AND POLYGUARD UNDERSLAB TRM
- DIG OUT AND EXPOSE EXISTING POLYGUARD UNDERSLAB TRM FOR ENTIRE TRENCH PERIMETER A MINIMUM 2" PAST ALL SAW CUTS
- APPROVED SUBSTRATES

UST6

SECTION @ UNDERSLAB TRM - SAW CUT THROUGH EXISTING MEMBRANE

The information provided is based on data and knowledge considered to be true and accurate and is offered for the users' consideration, investigation and verification, but we do not warrant the results to be obtained. Please read all data sheets, statements, recommendations or suggestions in conjunction with our conditions of sale, which apply to all goods supplied by us.	NOT TO SCALE
	EFFECTIVE DATE: 12/17/2024
	SUPERCEDES: 12/05/2024